

Assessment for Commercial Package Air Conditioners

Working Group for Risk Assessment of Lower Flammability refrigerant

Introduction

[Subject system] Commercial package air conditioners using A2L [Refrigerants (A2L)] R32, R1234yf, R1234ze(E)

[Conditions of risk assessment]

- 1st step: Standard case
- (IU)Ceiling cassette, (OU) Ground, No additional refrigerant charge
- 2nd step: Higher risk case less than 14kW system
- (IU)All type excluding floor mounted,€
- (OU) each floor installation, semi-underground, narrow space,
- (Max amount) Additional refrigerant charge on site
- 3rd step: Higher risk case less than 30kW system (IU)All type including floor mounted,
- (OU) each floor installation, semi-underground, narrow space,
- (Max amount) Additional refrigerant charge on site
- X(IU): Indoor units, (OU): Outdoor units

Conclusion

- **Standard case**: No problem without additional safety measures
- Higher risk case: Some conditions need the following safety measure

	Risk cases	< Dominant risk factors >		Usage stage	Service stages	Disposal stage
	Floor- stand indoor units	Cause	Leakage gas retention	Leakage gas retention	Human error	-
		Factor	High concentration	Air circulation by fan	Gas burner (brazing)	-
		Safety	"Unit's fan operating with a leak detector"		"Education for workers" and	
		measures	(Min. air flow: 10m³/min a	nd Min. velocity: 1.0m/s)	"Carrying a portable leak detector"	
	Outdoors Semi- underground installation	Cause	Leakage gas retention	Ignition sources	Human error	
		Factor	Air circulation/Ventilation	Boiler	Refrigerant recovery Gas burner	Refrigerant recovery Electrical wiring
		Safety	"Unit's fan operating with a leak detector"		"Education for workers" and	
		measures	(Minimum air velocity: 4.0m/s)		"Carrying a leak detector"	
	Outdoors Narrow space installation	Cause	Leakage gas retention	Ignition sources	Human error	
		Factor	Air circulation/Opening	Boiler	Refrigerant recovery Gas burner	Refrigerant recovery Electrical wiring
		Safety measures	"Opening of 0.6 m or more for one side"		"Education for workers" and "Carrying a portable leak detector"	

System

- Cooling capacity: 3.6 ~ 30.0 kW
- Charge amount of refrigerant: 2 ~ 19Kg
- Type: indoor single or 2~4 units in one room [simultaneous ON/OFF], outdoor single





• 1.03 \times 10⁻³ for slow leakage

• 1.50 \times 10⁻⁵ for rapid leakage

• 6.13 \times 10⁻² for slow leakage

• 1.34 \times 10⁻³ for rapid leakage

• 1.37 \times 10⁻⁴ for burst leakage

[Human error (by worker)]







Total number of unit :

about 0.6 billion units in Japan

• User: Office, Store, School, etc. (light commercial)





Distance between Buildings: 1.5 [m] Distance between obstacles: 5 [m]

Opening of an obstacle

amount of leakage





[Indoor]

Risk case

- Floor mounted type indoor unit [Outdoor]
- Semi-underground installation
- Narrow space installation

Leak rate

[Indoor unit]

[Outdoor unit]

 1.0×10^{-3}


Flammable volume-time integration


[Indoor]


- (Cassette 14kW,57.2m², R32:8kg) 1.53×10^{-1} [m³min]
- (Floor 5kW,14m², R32:3kg, Fan:OFF) 3.23 × 10² [m³min]
- (Floor 5kW,14m², R32:3kg, Fan:ON) None

[Outdoor]

- (Ground14kW, 50m², R32:8kg) 2.80×10^{-1} [m³min]
- (Semi -underground, 15m², R32:8kg) 5.97×10^3 [m³min]
- $(Narrow[open0.3m], 7.5m^2, R32:8kg) 9.75 \times 10^0 [m^3min]$
- $[Narrow[open0.6m], 7.5m^2, R32:8kg) 3.75 \times 10^0 [m^3min]$







[Spark]

- Match, Oil lighter
- Metal spark (by forklift)

Ignition source

- (Ref.) No ignition -
- Gas lighter
- Power Outlet
- Static electricity (by human)


[Open flame]


- Smoking equipment
- Combustion equipment (Heater, Boiler, Cooker etc.)
 - Gas burner (for brazing)

Risk assessment


[Standard case (Refrigerant: R32)] < RA Condition >







[Higher risk case (Refrigerant: R32)]



Tolerable, Result: Probability of Ignition > Not tolerable Repair/Service Life stage Logistics Installation Disposal Usage $\leq 1.3 \times 10^{-8}$ $\leq 1.3 \times 10^{-8}$ $(\leq 1.3 \times 10^{-8})$ $\leq 1.3 \times 10^{-9}$] $\leq 1.3 \times 10^{-8}$ [Tolerable level] with without without without Safety measures without without Office 6.61x10⁻¹⁰ 7.61×10⁻¹³ 4.82×10⁻¹² 1.90×10^{-12} None None None None 1.65×10⁻¹⁰ 7.97×10⁻¹¹ 7.33×10⁻¹² Kitchen 6.75×10⁻¹⁰ None None 1.04×10⁻⁹ 8.71×10⁻¹¹ 2.04×10⁻¹¹ karaoke 1.70×10⁻⁸ 2.45×10⁻¹⁰ 9.39×10⁻⁹ 1.00×10⁻¹² 9.28×10⁻⁹ 2.81x10⁻⁹ 2.99x10⁻⁹ None Restaurant 7.04×10^{-10} 2.30×10⁻⁹ 1.05×10⁻⁹ 3.11×10⁻⁹ None None None factory 6.68x10⁻¹⁰ 3.62×10⁻¹² 4.10×10⁻¹¹ 2.79×10⁻¹² Ice TS None None None 5.53×10⁻¹⁰ 8.02x10⁻¹⁰ 7.60×10^{-10} 2.61×10⁻¹⁰ Ground None None 6.15×10⁻¹⁰ Each floor 1.00×10⁻⁹ 1.48×10⁻⁹ 2.01×10⁻⁹ None None None 4.65×10⁻⁶ 1.14×10⁻⁹ 1.18×10⁻⁷ 2.93×10⁻⁹ 1.43×10⁻⁷ 1.59×10⁻⁹ Semi underground 8.49×10⁻⁹ 3.97×10⁻¹⁰ 1.91×10⁻⁸ 4.95×10⁻¹⁰ 2.61×10⁻⁸ 2.84×10⁻⁹ 5.34×10⁻⁹ Narrow space 8.30×10⁻¹¹ None 3.51×10⁻⁹ None Warehouse

Documentation

- Guideline of design construction for ensuring safety from commercial air conditioners using lower flammability (A2L) refrigerants JRA GL-16: 2016
 - Requirements for ensuring safety against refrigerant leakage from commercial air conditioners using lower flammability (A2L) refrigerants JRA 4070: 2016